

State Water Resources Control Board

October 12, 2016

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 8017 0699

Ms. Laura Ballesteros
Development Specialist
Riverside County Economic
Development Agency
3133 Mission Inn Avenue
Riverside, CA 92507
lballesteros@rivcoeda.org

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT COUNTY OF RIVERSIDE SOUTHWEST COUNTY JUSTICE
JUVENILE, 30755 AULD ROAD #1313, MURRIETA**

Dear Ms. Ballesteros:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on September 21, 2016, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and title 23, California Code of Regulations (CCR), chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Update Tank Forms – The primary product and vent lines state fiberglass in CERS when steel was observed during the inspection.	Diesel	September 21, 2016	Ongoing	H&SC 25286(a); 23 CCR 2711(a)

You are directed to correct the ongoing violation and submit compliance documentation to the State Water Board and Riverside County Department of Environmental Health within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violation has been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
1001 I Street
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov

Local CUPA

Mr. Jeff Johnson
Program Chief
Riverside County Department of
Environmental Health
4065 County Circle Drive
Riverside, CA 92503
jeffjohnson@rivcocha.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Mr. Jeff Johnson
Program Chief
Riverside County Department of
Environmental Health
jeffjohnson@rivcocha.org

Mr. Manny Moran
Building Engineer
Riverside County Economic
Development Agency
mmoran@rivcoeda.org